

**Project:**

Order No: Premio EPS100 Compression test

Part No: P100/2021\_03\_03


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 03. 03. 11:15:18

**Chart:**



**Results:**

| Nom                                | Stress [kPa]<br>,max. | Displacement<br>[mm] ,max. |
|------------------------------------|-----------------------|----------------------------|
| Premio<br>EPS100/2021_0<br>3_03(2) | 109,70                | 9,99                       |
| Premio<br>EPS100/2021_0<br>3_03(3) | 111,86                | 9,99                       |
| Premio<br>EPS100/2021_0<br>3_03(4) | 110,91                | 10,00                      |
| <b>Max.</b>                        | 111,86                | 10,00                      |
| <b>Min.</b>                        | 109,70                | 9,99                       |
| <b>Mean</b>                        | 110,82                | 9,99                       |