

**Project:**

Order No: Premio EPS80 Compression test

Part No: P80/2021\_05\_12


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 05. 12. 13:52:58

**Chart:**



**Results:**

| Nom                           | Stress [kPa]<br>,max. | Displacement<br>[mm] ,max. |
|-------------------------------|-----------------------|----------------------------|
| Premio<br>EPS80/2021_05_12(1) | 86,09                 | 9,99                       |
| Premio<br>EPS80/2021_05_12(2) | 83,25                 | 9,99                       |
| Premio<br>EPS80/2021_05_12(4) | 81,87                 | 9,99                       |
| Max.                          | 86,09                 | 9,99                       |
| Min.                          | 81,87                 | 9,99                       |
| Mean                          | 83,74                 | 9,99                       |