

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_06_14(1)


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 06. 14. 10:34:16

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_06 _14(1)	86,58	9,99
Premio EPS80/2021_06 _14(2)	88,30	10,00
Premio EPS80/2021_06 _14(3)	89,69	9,99
Max.	89,69	10,00
Min.	86,58	9,99
Mean	88,19	9,99