

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2022_01_20


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2022. 01. 20. 11:03:04

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2022_12 _19/0.0(1)	89,60	9,99
Premio EPS80/2022_12 _19/0.0(3)	92,29	10,00
Premio EPS80/2022_12 _19/0.0(5)	84,12	9,99
Max.	92,29	10,00
Min.	84,12	9,99
Mean	88,67	9,99