


Project:

Order No: Premio EPS80 Compression test
Part No: Premio EPS80/2023_04_30
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023. 04. 30. 14:35:49

Chart:



Results:

Nom	Stress [kPa] ,max.	
Premio EPS80 /2023_04_21(1)	87,58	
Premio EPS80 /2023_04_30(2)	87,03	
Premio EPS80 /2023_04_30(3)	87,46	
Max.	87,58	0
Mean	87,36	0