


Project:

Order No: Premio EPS 100 Compression test
Part No: Premio EPS 100 2023_08_15
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.08.15.

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS 100_2023_08_15	106,62	9,99
Premio EPS 100_2023_08_15	109,68	9,99
Premio EPS 100_2023_08_15	111,51	9,99
Premio EPS 100_2023_08_15	106,82	9,99
Premio EPS 100_2023_08_15	112,30	9,99
<i>Mean</i>	109,39	9,99